



Yvonne Perez <yperez@sylvan.k12.ca.us>

Stockard Coffee

1 message

SEAN SMITH <ssmith@sylvan.k12.ca.us>

Thu, Oct 5, 2017 at 10:16 AM

To: Yvonne Perez <yperez@sylvan.k12.ca.us>, Jason Gales <JGales@sylvan.k12.ca.us>

Hi,

I had a look around at the 20's wing at Stockard Coffee this morning.

Timer for exhaust fan is operational and functioning correctly - it is set to run from 6pm to 7am Monday through Friday.



The building has multiple (3 that I saw) vertical ducts going from the crawlspace to the exhaust fan, as seen in the left side of this photo:



Here is the rooftop exhaust fan:



The fan is fully functional at this time. (Video clip attached)

--

Sean Smith

Maintenance & Operations
Chapter President CSEA Sylvan 73
Sylvan Union School District
2800 Coffee Road
Modesto, CA 95355

209-652-0827
209-574-5685

e-mails are nice but Work Orders are what gets the job done!

This message, including any attachments, is intended solely for the use of the named recipient(s) and may contain confidential and/or privileged information. Any unauthorized review, use, disclosure or distribution of this communication(s) is expressly prohibited. THIS INCLUDES FORWARDING! If you are not the intended recipient, please contact the sender by reply e-mail and destroy any and all copies of the original message.

 **SCFANrunning.mp4**
12566K