




# CHANGE ORDER #5

## ENCASE SHALLOW STORM DRAIN LINE IN CONCRETE

<b>ISSUE:</b>	<b>DATE: 2/1/2018</b>
The contractor and project team identified that there was not enough cover over the storm drain line from the campus into the project. The contractor and design team suggest that that concrete be placed to encase the pipe coming from the existing DI on the South West corner going to the bio swale.	
<b>RESPONSE:</b>	<b>DATE: 2/1/2018</b>
The District agrees to the proposed solution.	

<b>PROJECT CONTRACT TOTALS:</b>	
The original contract sum	<b>\$449,493.00</b>
Net change by previously approved change orders	<b>\$14,577.00</b>
Contract sum prior to this change order	<b>\$464,070.00</b>
Contract sum will be increased by this change order by the amount of	<b>\$1,950.00</b>
The new total contract sum including this change order will be	<b>\$466,020.00</b>

Upon signing below by the Contractor and the Owner, the above noted contract is hereby amended according to this Change Order and the terms of the Agreement.

<b>APPROVALS:</b>	
<b>OWNER REPRESENTATIVE - DISTRICT</b>	<b>CONTRACTOR</b>
Nelson Payton, Director MOT, PRUSD	Paul Viborg, Viborg Sand and Gravel, Inc.
DATE:	DATE:
<b>DSA INSPECTOR</b>	<b>ARCHITECT</b>
Carl Adams	Wes Arola, RRM Design Group
	
DATE:	DATE: 3/22/2018
<b>BOARD APPROVAL DATE:</b>	