

<u>Item #1</u>	Furnish and install new transition duct to relocate existing supply duct to match the AC unit opening. Provide insulation and duct sealant. Requested by Engineer.	ADD	\$4,421.00
<u>Item #2</u>	Furnish and install thirty-four (34) additional duct support in lieu of the E. blocking that was not secured into the roof. Requested by Engineer.	ADD	\$2,599.00
<u>Item #3</u>	Install eight (8) undelivered hinged access panels in lieu of the existing sheet-metal caps above economizer/power exhaust for future filter changeout. Requested by Engineer.	ADD	\$7,078.00
<u>Item #4</u>	Furnish and install new raceway in the multi-purpose rooms for AC-3 and AC-4 at Ellen Feickert Elementary and AC-5 at Florence Markofer Elementary due to damaged and obstructed existing infrastructure. Requested by Engineer.	ADD	\$3,353.00