

• donald t. kan
civil engineer
rce 36676

• henry wong
civil engineer
rce 31008



• david j. starck
architect
c 22903

• allan v. stevenson
civil engineer
rce 61758

December 20, 2018

BID DATE: January 8, 2019
BID TIME: 1:30:00 pm

File No.: 50-59
App. No.: 02 – 116801



ADDENDUM #1

To the PLANS and SPECIFICATIONS
for the
SYLVAN UNION SCHOOL DISTRICT

SYLVAN ELEMENTARY SCHOOL

Window Replacement - Rebid

GENERAL

The following addendum to the Plans and Specifications shall take precedence over and be amended to the original Plans and Specifications.

ARCHITECTURAL:

ITEM #1.0: *Clarification: Paint:* All trim and other surfaces on the interior and exterior of the building that have been modified or added shall be painted / touched up to match the existing paint color & sheen.

ITEM #1.1: *Clarification: Windows:* Windows shall be Kawneer 451-T – Center Set, Screw Spline per Window Note #2 on Sheet A-1. (or approved equal) Glazing shall be as listed on sheet A-1. Windows shall match window system installed during previous modernization. Contractor shall visit the site to ensure product proposed to be provided matches product on site.

ITEM #1.2: *Clarification: Glazeguard Glazing:* 1' thick aluminum window panels listed as Glazeguard on sheet A-1 shall be 1" GlazeGuard 1000 WR+ panels by Citadel Architectural Products (or approved equal) with Smooth Aluminum finish on both interior and exterior surface.

SPECIAL NOTE:

It is the responsibility of each Bidder to acknowledge all addenda on the BID FORM.

2237 scenic drive, modesto, ca 95355 p: 209•523•8323 f: 209•529•7804

6130 freeport blvd., suite 101, sacramento, ca 95822 p: 916•429•2800 f: 916•429•2553